

#### Weidmüller Interfaces GmbH & Co. KG

Postfach 3030

32760 Detmold

Tel. +49 5231 14-0

Fax. +49 5231 14-2083

info@weidmueller.com

www.weidmueller.com

## **Product image**



















simillar to illustration

Connect efficiently - in a small space: female header with spring connection (PUSH IN) as a plug-in connection level; used together with male headers in 3.50 mm pitch.

### **General ordering data**

Version	PCB plug-in connector, female plug, 3.50 mm, Number of poles: 6, 180°, PUSH IN with actuator, Tension-clamp connection, Clamping range, max.: 1.5 mm², Box
Order No.	<u>2459090000</u>
Type	BLF 3.50/06/180 SN OR BX
GTIN (EAN)	4050118474442
Qty.	84 pc(s).
Product data	IEC: 320 V / 17.5 A / 0.14 - 1.5 mm <sup>2</sup> UL: 300 V / AWG 26 - AWG 16
Packaging	Box



#### Weidmüller Interfaces GmbH & Co. KG

Postfach 3030

32760 Detmold

# **Technical data**

Tel. +49 5231 14-0

Fax. +49 5231 14-2083

### **Dimensions and weights**

Depth	22.7 mm	Depth (inches)	www.weidmuelle894ninch
Height	9 mm	Height (inches)	0.354 inch
Width	21 mm	Width (inches)	0.827 inch
Net weight	<b>4.</b> 2 g		

### **System Parameters**

Product family	OMNIMATE Signal - series BL/SL 3.50
Type of connection	Field connection
Wire connection method	PUSH IN with actuator, Tension-clamp connection
Pitch in mm (P)	3.5 mm
Pitch in inches (P)	0.138 inch
Conductor outlet direction	180°
Number of poles	6
L1 in mm	17.5 mm
L1 in inches	0.689 inch
Number of rows	1
Pin series quantity	1
Rated cross-section	1.5 mm <sup>2</sup>
Touch-safe protection acc. to DIN VDE 57 106	Safe from finger touch
Touch-safe protection acc. to DIN VDE 0470	IP 20
Volume resistance	≤5 mΩ
Can be coded	Yes
Stripping length	8 mm
Stripping length tolerance	min. 0 mm
	max. 1 mm
Screwdriver blade	0.4 x 2.5
Screwdriver blade standard	DIN 5264-A
Plugging cycles	25
Plugging force/pole, max.	6 N
Pulling force/pole, max.	6 N

### **Material data**

Insulating material	PA GF	Colour	orange
Colour chart (similar)	RAL 2000	Insulating material group	II
Comparative Tracking Index (CTI)	≥ 400, ≤ 600	UL 94 flammability rating	V-0
Contact material	Copper alloy	Contact surface	tinned
Storage temperature, min.	-40 °C	Storage temperature, max.	70 °C
Operating temperature, min.	-50 °C	Operating temperature, max.	120 °C
Temperature range, installation, min.	-30 °C	Temperature range, installation, max.	100 °C

### **Conductors suitable for connection**

Clamping range, min.	0.14 mm <sup>2</sup>
Clamping range, max.	1.5 mm <sup>2</sup>
Wire connection cross section AWG,	AWG 26
min.	
Wire connection cross section AWG,	AWG 16
max.	
Solid, min. H05(07) V-U	0.14 mm²
Solid, max. H05(07) V-U	1.5 mm <sup>2</sup>
Flexible, min. H05(07) V-K	0.14 mm <sup>2</sup>



#### Weidmüller Interfaces GmbH & Co. KG

Postfach 3030

32760 Detmold

# **Technical data**

Tel. +49 5231 14-0

	Fax. +49 5231	14-2083
1.5 mm <sup>2</sup>		
4, 0.25 mm²	info@weidmuelle	er.com
1, 1 mm²	www.weidmuelle	er.com
0.25 mm <sup>2</sup>		
1 mm <sup>2</sup>		
2.4 mm x 1.5 mm		
Cross-section for conductor connection	Туре	fine-wired
	nomina <b>l</b>	0.25 mm <sup>2</sup>
wire end ferrule	Stripping length	nominal 10 mm
	Recommended wire- end ferrule	H0,25/12 HBL
Cross-section for conductor connection	Туре	fine-wired
	nomina <b>l</b>	0.34 mm <sup>2</sup>
wire end ferrule	Stripping length	nominal 10 mm
	Recommended wire- end ferrule	H0,34/12 TK
Cross-section for conductor connection	Туре	fine-wired
	nomina <b>l</b>	0.5 mm <sup>2</sup>
wire end ferrule	Stripping length	nominal 10 mm
	Recommended wire- end ferrule	H0,5/14 OR
Cross-section for conductor connection	Туре	fine-wired
	nomina <b>l</b>	0.75 mm <sup>2</sup>
wire end ferrule	Stripping length	nominal 10 mm
	Recommended wire- end ferrule	H0,75/14T HBL
Cross-section for conductor connection	Туре	fine-wired
	nominal	1 mm <sup>2</sup>
wire end ferrule	Stripping length	nominal 10 mm
	Recommended wire- end ferrule	H1,0/14 GE
	4, 0.25 mm²  1, 1 mm²  0.25 mm²  1 mm²  2.4 mm x 1.5 mm  Cross-section for conductor connection wire end ferrule  Cross-section for conductor connection	1.5 mm² 4, 0.25 mm² 1 mm² 2.4 mm x 1.5 mm  Cross-section for conductor connection

Reference text

The outside diameter of the plastic collar should not be larger than the pitch (P), Length of ferrules is to be chosen depending on the product and the rated voltage.

### Rated data acc. to IEC

tested acc. to standard	IEC 60664-1, IEC 61984	Rated current, min. number of poles (Tu=20°C)	17.5 A
Detect a construction of color	IEC 00004-1, IEC 01304	<u> </u>	17.5 A
Rated current, max. number of poles (Tu=20°C)	14.7 A	Rated current, min. number of poles (Tu=40°C)	17.1 A
Rated current, max. number of poles (Tu=40°C)	13.1 A	Rated voltage for surge voltage class / pollution degree II/2	320 V
Rated voltage for surge voltage class / pollution degree III/2	160 V	Rated voltage for surge voltage class / pollution degree III/3	160 V
Rated impulse voltage for surge voltage class/ pollution degree II/2	2.5 kV	Rated impulse voltage for surge voltage class/ pollution degree III/2	2.5 kV
Rated impulse voltage for surge voltage class/ contamination degree III/3	2.5 kV	Short-time withstand current resistance	1 x 1s with 120 A

### Rated data acc. to CSA

Rated voltage (Use group B / CSA)	300 V	Rated voltage (Use group C / CSA)	50 V
Rated voltage (Use group D / CSA)	300 V	Rated current (Use group B / CSA)	10 A
Rated current (Use group D / CSA)	10 A	Wire cross-section, AWG, min.	AWG 26
Wire cross-section, AWG, max.	AWG 16		



#### Weidmüller Interfaces GmbH & Co. KG

Postfach 3030

32760 Detmold

**Technical data** 

Tel. +49 5231 14-0

Fax. +49 5231 14-2083

ь	,,	C	и	1	n	0

Packaging Box VPE length www.weidmuelled 2 mm

VPE width 136 mm VPE height 30 mm

ı	У	p	е	t	е	S	ts
---	---	---	---	---	---	---	----

Visual and dimensional test	Standard	IEC 60512-1-1:2002-02
	Test	dimensional inspection
	Evaluation	passed
	Standard	IEC 60512-1-2:2002-02
	Test	weight check
	Evaluation	passed
	Standard	IEC 61984:2001-10 section 6.2
	Test	visual examination
	Evaluation	passed
Test: Durability of markings	Standard	IEC 60068-2-70:1995-12 test Xb
	Test	mark of origin, type identification, pitch, type of material, date clock, approval marking UL, approval marking CSA, durability
	Evaluation	available
Test: Misengagement (Non- interchangeability)	Standard	IEC 60512-13-5:2006-02
	Test	intentional plugging
	Evaluation	passed
	Test	180° turned without coding elements
	Evaluation	passed
	Test	180° turned with coding elements
	Evaluation	passed
	Test	visual examination
	Evaluation	passed
Test: Clampable cross section	Standard	IEC 60999-1:1999-11 section 9.1, IEC 60947-1:2011-03 section 8.2.4.5.1
	Conductor type	Type of conductor solid 0.14 mm <sup>2</sup> and conductor cross-section
		Type of conductor stranded 0.14 mm <sup>2</sup> and conductor cross-section
		Type of conductor solid 1.5 mm <sup>2</sup> and conductor cross-section
		Type of conductor stranded 1.5 mm <sup>2</sup> and conductor cross-section
		Type of conductor AWG 26/1 and conductor cross-section
		Type of conductor AWG 26/19 and conductor cross-section
		Type of conductor AWG 16/1 and conductor cross-section
		Type of conductor AWG 16/19 and conductor cross-section



### Weidmüller Interfaces GmbH & Co. KG

Postfach 3030

32760 Detmold

Technical data		Tel. +49 5231 14-0
		Fax. +49 5231 14-2083
Test for damage to and accidental loosening of conductors	Standard	IEC 60999-1:1999-11 section 9.4 bzw. sectio 8.10 info@weidmueller.com
	Requirement	0.3 kg
	Conductor type	Type www.wieidonuellertwo.5V-U0.5 and conductor cross-section
		Type of conductor H05V-K0.5 and conductor cross-section
	Evaluation	passed
	Requirement	0.4 kg
	Conductor type	Type of conductor H07V-U1.5 and conductor cross-section
		Type of conductor H07V-K1.5 and conductor cross-section
		Type of conductor AWG 16/1 and conductor cross-section
		Type of conductor AWG 16/19 and conductor cross-section
	Evaluation	passed
	Requirement	0,2 kg
	Conductor type	Type of conductor AWG 26/1 and conductor cross-section
		Type of conductor AWG 26/19 and conductor cross-section
	Evaluation	passed
ull-out test	Standard	IEC 60999-1:1999-11 section 9.5
	Requirement	≥20 N
	Conductor type	Type of conductor H05V-U0.5 and conductor cross-section
		Type of conductor H05V-K0.5 and conductor cross-section
	Evaluation	passed
	Requirement  Conductor type	≥40 N  Type of conductor H07V-U1.5  and conductor cross- section
		Type of conductor H07V-K1.5 and conductor cross-section
		Type of conductor AWG 16/1 and conductor cross-section
		Type of conductor AWG 16/19 and conductor cross-section
	Evaluation	passed
	Requirement	≥10 N
	Conductor type	Type of conductor AWG 26/1 and conductor cross-section
		Type of conductor AWG 26/19 and conductor cross-section
	Evaluation	passed



#### Weidmüller Interfaces GmbH & Co. KG

27-46-02-02

Postfach 3030

32760 Detmold

# **Technical data**

Tel. +49 5231 14-0

Fax.	+49 5231	14-2083

Classifications			info@weidmueller.com	
ETIM 6.0	EC002638	ETIM 7.0	www.weidmue <b>llegggg26</b> 38	
ETIM 8.0	EC002638	ECLASS 9.0	27-44-03-09	
ECLASS 9.1	27-44-03-09	ECLASS 10.0	27-44-03-09	

ECLASS 12.0

#### Important note

ECLASS 11.0

IPC conformity	Conformity: The products are developed, manufactured and delivered according international recognized
	standards and norms and comply with the assured properties in the data sheet resp. fulfill decorative properties
	in accordance with IPC-A-610 "Class 2". Further claims on the products can be evaluated on request.
Notes	Additional variants on request

- Gold-plated contact surfaces on request
- · Rated current related to rated cross-section & min. No. of poles.
- Wire end ferrule without plastic collar to DIN 46228/1
- Wire end ferrule with plastic collar to DIN 46228/4
- P on drawing = pitch

27-46-02-02

- Rated data refer only to the component itself. Clearance and creepage distances to other components are to be designed in accordance with the relevant application standards.
- The test point can only be used as potential-pickup point.
- Long term storage of the product with average temperature of 50 °C and average humidity 70%, 36 months

#### **Approvals**

Approvals	c <b>Al</b> s
ROHS	Conform
UL File Number Search	UL Website
Certificate No. (cURus)	E60693

#### Downloads

Engineering Data	CAD data – STEP
Catalogues	Catalogues in PDF-format

**Drawings** 



# BLF 3.50/06/180 SN OR BX

#### Weidmüller Interfaces GmbH & Co. KG


Postfach 3030

32760 Detmold

Tel. +49 5231 14-0

Fax. +49 5231 14-2083

## Dimensional drawing @weidmueller.com



### **Product benefits**

