SAFETY ORGANIZATIONS

THIS FILTER HAS BEEN FORMALLY RECOGNIZED, CERTIFIED OR APPROVED BY THE LISTED AGENCY. THEREFORE, ALL TEST/REQUIREMENTS SPECIFIED IN THE LATEST REVISION OF THE FOLLOWING AGENCY STANDARDS HAVE BEEN MET:

UL RECOGNIZED: UL 1283 CSA CERTIFIED: CSA C22.2 No. 8 VDE APPROVED: EN 60939-2

OPERATING SPECIFICATIONS

LINE CURRENT/VOLTAGE: 20 AMP, 120/250 VAC, 16 AMP/40°C, 250 VAC

LINE FREQUENCY:

COMMON

dΒ

DIFF ďΒ

/

NOTE PROJECTION

50-60Hz

MAXIMUM LEAKAGE CURRENT, EACH LINE TO GROUND:

2µА @ 120V 60Hz @ 250V 50Hz 5µА

OPERATING AMBIENT TEMP. RANGE: -10°C TO +40°C @ RATED CURRENT, In.

RELIABILITY SPECIFICATIONS:

STORAGE TEMPERATURE: -40°C TO +85°C HUMIDITY: 21 DAYS № 40°C 95% RH. CURRENT OVERLOAD TEST: 6 TIMES In FOR

CUSTOMER DRAWING CATALOG # 20SRBS1 APPRVD DATE ECN# 15-000476 1190CT15 TAM

POWER LINE FILTER

13,40614

DRAVING MINITES

20SRBS1

1

TE PART NO.: 5-1609152-9

1:1 OATE:

STATE:

TEST SPECIFICATIONS:

INDUCTANCE: N/A CAPACITANCE: (MEASURED @ 1KHz, 0.250VAC MAX., 25°C±1°C)

LINE TO GROUND:

N/A

LINE TO LINE:

±20% N/A ±20%

DISCHARGE RESISTOR:

N/A M A

L/G AND L/L I.R. NO DISCHARGE RESISTOR:

6000M₁ (MIN.) @ 100VDC,


20°C AND 50% RH

RECOMMENDED RECEIVING INSPECTION HIPOT:

LINE TO GROUND: 1500 VAC FOR I MINUTE LINE TO LINE: 1450 VDC FOR I MINUTE

FILTER APPROVAL:

THE BEST WAY TO SELECT AND QUALIFY A FILTER IS FOR YOUR ENGINEERING TO TEST THE UNIT IN YOUR EQUIPMENT.



NOTES:

20SRBS1 Lockd

THIS INFORMATION IS CONFIDENTIAL AND PROPRIETARY TO TYCH ELECTROHICS DEPORATION AND ITS WORLDWISE SISSIDIARIES AND AFFILIATES. IT HAY NOT BE DISCUSSED TO ANOVE OTHER THAN TYCH ELECTROHICS PERSONAE. IT HAY NOT WRITTEN AUTHORIZATION FROM TYCH ELECTROHICS CORPORATION.

WILTERS AUTHORIZATION FROM TYCH ELECTROHICS CORPORATION.